

REQUEST FOR BOARD ACTION

Henderson County Board of Commissioners

Meeting Date: March 19, 2008

Subject: Water Line Extension – The Sanctuary at Mills River

Attachments: Vicinity Map
Engineer's Report
Project Summary
Project Map
County Review Sheet

Summary of Request:


The City of Hendersonville has requested that the County comment on the proposed water line extension for the Sanctuary at Mills River. The proposed water line is 1,700 linear feet and includes two fire hydrants. Its location within the urban services area is consistent with the Henderson County 2020 Comprehensive Plan. A City of Hendersonville Project Summary Sheet, with supporting documents and County Review Sheet with Staff comments, are attached for Board review and action.

Board Action Request:

Action by the Board of Commissioners is needed to either grant or deny this request. If the Board decides to approve the requested extension the following motion has been provided.

Suggested Motion:

I move that the Board approve the Sanctuary at Mills River water line extension and direct Staff to convey the County's comments to the City of Hendersonville.



Sanctuary at Mills River

OWNER/DEVELOPER: M & M Land Developers of WNC, LLC

AGENT: Mark Gibbs

CURRENT ZONING: R-2

SEWER SYSTEM: Private

ROAD SYSTEM: Public

Legend

- The Sanctuary at Mills River
- Proposed Water Line Extension
- Existing Hendersonville Water Line
- Streets
- Parcels
- Urban Services Area



William G. Lapsley & Associates, P.A.

Consulting Civil Engineers and Land Planners


William G. Lapsley, P.E.
William R. Buie, P.E.
G. Thomas Jones III, P.E.
Donald L. Hunley, P.E.

TO: Lee Smith, Utilities Director
Water & Sewer Department
City of Hendersonville

FROM: **William G. Lapsley, PE**

DATE: **Thursday, February 21, 2008**

SUBJECT: **The Sanctuary at Mills River
PIN # 9650-19-0825
WATER UTILITY EXTENSION**



An extension of the existing water main(s) located **on North Rugby Road** is required to provide water service to the above referenced project. This project is proposed to be a **single family residential** development. The water extension will serve a total of **ten (10) units**. The proposed site is currently owned and being developed by:

Mark Gibbs, Manager Member
M & M Land Developer's of WNC, LLC
3702 Spartanburg Highway
Hendersonville, North Carolina 28731
William G. Lapsley, PE
828-687-7177
wlapsley@wgla.com

The sewer service for this project will be provided by individual on-site septic systems.

At the present time, Mark Gibbs will be responsible for signing the Water Utility Extension Agreement (WUEA) with the City of Hendersonville.

The project will consist of **approximately 1,700 LF of 8 inch(180 LF), 6 inch(1,000 LF), and 2 inch(500 LF) diameter water lines, 3 inch(1 EA), 6 inch(2 EA) and 2 inch (1 EA) gate valves, fire hydrants (2 ea-500 gpm), air release valve(1 EA) and 2 inch flush hydrant(1 EA). There will be ten (10) water services with an estimated domestic water supply demand of 50 gpm.** For more information regarding this proposed project see the accompanying preliminary plans.

This project is estimated to be completed **60 days** after final grading has been completed, assuming favorable weather conditions. I, or an authorized representative of my company, will be observing and monitoring the progress of construction for this project. Should you have any questions, concerns or comments regarding this project please feel free to contact me.

**ENGINEER'S REPORT
THE SANCTUARY AT MILLS RIVER
WATER SYSTEM IMPROVEMENTS**

FEBRUARY, 2008



1. NAME AND ADDRESS OF APPLICANT

City of Hendersonville
P.O. Box 1670
Hendersonville, NC 28793

2. PROJECT DESCRIPTION AND INTRODUCTION

This project is located off of North Rugby Road in Henderson County. The proposed development covers approximately 11 acres. Individual water meter service connections will be provided for each lot. The proposed water line extension will include approximately 1700 lf of 8"Ø, 6"Ø and 2"Ø water mains (DIP/CL350 & PVC/DR13.5); 8"Ø gate valve (1 each), 6" gate valve (2 ea), 2"Ø gate valve (1 ea), two (2) fire hydrants, air release valve (1 ea) and 2"Ø flush hydrant (1 ea.).

3. DESCRIPTION OF FUTURE SERVICE AREAS

The service area for this project is approximately 11 acres. The existing water supply at this site is adequate to meet the project needs.

4. PRESENT AND ANTICIPATED WATER DEMANDS

This water system will serve ten (10) single family homes. The anticipated water usage is 4,000 gallons per day. (10 ea. @ 400 gpd)

5. CHARACTER OF THE SOURCE OF SUPPLY

The water supply for this project is from the City of Hendersonville Water Treatment Plant.

6. AGREEMENTS TO PURCHASE WATER

Not Applicable

7. USEFUL LIFE OF FACILITIES

The useful life of the water line for this project is expected to be 50 years minimum.

8. **MAXIMUM DAILY TREATED WATER SUPPLY AND MAXIMUM DAILY DEMAND**

The maximum daily treated water supply for the City of Hendersonville water plant is 12 MGD. The average demand is 7.2 MGD, with a daily peak (for the year) of 9.5 MGD.

9. **IDENTIFICATION & DESCRIPTION OF THE SERVICE AREA**

The service area for this project is the Sanctuary at Mills River Subdivision.

10. **CONSIDERATION OF ALTERNATIVES TO CONSTRUCTING A NEW WATER SYSTEM**

Not Applicable

11. **POPULATION RECORDS AND TRENDS**

According to the Office of State Planning, the population of the City of Hendersonville in 1998 was 9,538 person. The growth rate from 1990 to 1998 was 30.9%

12. **PRESENT AND FUTURE YIELD FROM THE SOURCES OF SUPPLY**

The City of Hendersonville Water Plant currently draws water from the Mills River. The present and future yield of the source of supply is expected to be adequate for the City of Hendersonville's needs.

13. **PROPOSED WATER TREATMENT PROCESSES**

Not Applicable

14. **DESIGN BASIS**

The design basis for this project is to provide adequate flow and 30 psi minimum throughout the system.

15. **PRIORITIZED LIST OF INFRASTRUCTURE IMPROVEMENTS**

Not Applicable

TECHNICAL SPECIFICATIONS
for
WATER DISTRIBUTION SYSTEM
to serve
THE SANCTUARY AT MILLS RIVER

City of Hendersonville
Henderson County, North Carolina



A handwritten signature in black ink is written over a circular professional seal. To the right of the signature, the date "2/21/08" is handwritten. The seal is circular with a dotted border and contains the text "SEAL", "ENGINEER", and "GREGORY LAPSLEY" in a circular arrangement.

WILLIAM G. LAPSLEY & ASSOCIATES, P.A.
CONSULTING ENGINEERS
Two Town Square Blvd., Suite 320
Asheville, NC 28803

February, 2008

06200.1 APPLICABLE AWWA STANDARDS

C600: Installation of Ductile-Iron Water Mains and Their Appurtenances

C605: Underground Installation of Polyvinyl Chloride (PVC) Pressure Pipe and Fittings for Water

C651: Disinfecting Water Mains (Preventive and Corrective Measures During Construction)

06200.2 TRENCH DEPTH AND COVER

The minimum allowable soil cover over a water main must be 30". The minimum trench depth must be 4'.

06200.3 HANDLING AND STORING MATERIALS

The Contractor shall use care unloading pipe to avoid damage. Pipe shall not be placed within pipe of a large size and shall not be rolled or dragged over gravel or rock during handling. The Contractor shall store the pipe on sills above storm drainage level and deliver for laying after the trench is excavated. When any joint or section of pipe is damaged during transporting, unloading, handling, or storing, the undamaged portions of the joint or section may be used where partial lengths are needed, or if damaged sufficiently, the Engineer will reject the joint or section as being unfit for installation.

If any defective pipe is discovered after installation, it shall be removed and replaced with sound pipe or shall be repaired by the Contractor in an approved manner and at his own expense.

06200.4 SAW CUTTING ASPHALT

Refer to Section 250-2 of the NCDOT Standard Specification for Roads and Structures.

06200.5 PREPARATION OF PIPE FOUNDATION

The preparation of the pipe bedding shall be in accordance with the typical trench cross-sections as shown on the plans for the type of pipe being installed.

The pipe foundation shall be prepared to be uniformly firm and shall be true to the lines and grades as shown on the plans. Any deviation or field adjustment will require the approval of the Engineer. When an Inspector is present on the site and is so requested by the Contractor, he shall check the position of grades and lines but the Contractor shall be responsible for the finished work conforming to exact and proper line and grade.

Whenever the nature of the ground will permit, the excavations at the bottom of the trench shall have the shape and dimensions of the outside the pipe, care being taken to secure a firm bearing support uniformly throughout the length of the pipe. A space shall be excavated under and around each bell to sufficient depth to relieve it of any load and to allow ample space for filling and finishing the joint. The pipe, when thus bedded firmly, shall be on the exact grade.

In case the bed shaped in the bottom of the trench is too low, the pipe shall be completely removed from position, and earth of suitable quality shall be placed and thoroughly tamped to prepare a new foundation for the pipe. In no case shall the pipe be brought to grade by blocking up under the barrel or bell of same, but a new and uniform support must be provided for the full length of the pipe. Where rock or boulders are encountered in the bottom of the trench, the same shall be removed to such depth that no part of the pipe,

when laid to grade, will be closer to the rock or boulders than six (6) inches. A suitably tamped and shaped foundation of approved material shall be placed to bring the bottom of the trench to proper subgrade over rock or boulders.

Where the foundation material is found to be of poor supporting value, the Engineer may make minor adjustments in the location of the pipe to provide a more suitable foundation. Where this is not practical, the foundation shall be conditioned by removing the existing foundation material by undercutting to the depth as directed by the Engineer, within limits established on the plans, and backfilling with either an approved material secured from unclassified excavation or borrow excavation at the nearest accessible location along the project, or foundation conditioning material consisting of crushed stone or gravel approved by the Engineer as being suitable for the purpose intended. The selection of the type of backfill material to be used for foundation conditioning will be made by the Engineer.

The Contractor shall remove all water which may be encountered or which may accumulate in the trenches by pumping or bailing and no pipes shall be laid until the water has been removed from the trench. Water so removed from the trench must be disposed of in such a manner as not to cause injury to work completed or in progress.

Whenever the bottom of the trench shall be of such nature as to provide unsatisfactory foundation for the pipe, the Engineer will require the pipe to be laid on the timber or concrete cradle foundations. Such foundations whether of single plank, plank cradle supported by piles, or poured concrete cradle, shall be placed by the Contractor and compensation will be allowed the Contractor for the work.

6200.6

LAYING PIPE

All pipe is to be installed in strict accordance with the manufacturer's recommendations and the contract material specifications. Installation manuals from various material suppliers are required to be furnished to the Engineer for his review and approval prior to installation of any materials. No pipe shall be laid except in the presence of the Engineer or his inspector or with special permission from the Engineer. Water lines shall have thrust blocks constructed at all tees, "Y's", bends, and valves as shown on the plans.

Proper tools, implements and facilities satisfactory to the Engineer shall be provided and used for the safe and convenient prosecution of pipe laying. All pipe, fittings, valves, and other materials used in the laying of pipe will be lowered into the trench piece by piece by means of suitable equipment in such a manner to prevent damage to the pipe, materials, to the protective coating on the pipe materials, and to provide a safe working condition to all personnel in the trench. Each piece of pipe being lowered into the trench shall be clean and free of defects. It shall be laid on the prepared foundations, as specified elsewhere to produce a straight line on a uniform grade, each pipe being laid so as to form a smooth and straight inside flow line. Pipe shall be removed at any time if broken, injured or displaced in the process of laying same, or of backfilling the trench.

When cutting short lengths of pipe, a pipe cutter as approved by the Engineer will be used and care will be taken to make the cut at right angles to the center line of the pipe or on the exact skew as shown on the plans. In the case of push-on pipe, the cut ends shall be tapered with a portable grinder, or coarse file to match the manufactured taper.

All pipe joints shall be constructed in strict accordance with the pipe manufacturer's specifications and materials and any deviation must have prior approval of the Engineer.

The maximum deflection per joint of flexible joint pipe shall be that deflection recommended by the manufacturer. No deflection shall be allowed in galvanized steel pipe joints or concrete pressure pipe joints.

06200.7 BACKFILLING

Methods of backfilling shall be in strict accordance with these specifications and the pipe manufacturer's recommendations. Where there is a conflict between the two, the manufacturer's recommendations shall govern.

All backfill shall be from the excavation and shall be free from organic matter and rocks larger than three inches in the largest dimension and shall contain more than 50 percent of minus ¾ inch material. Backfill shall be moisture conditioned to achieve a moisture content at or near the laboratory optimum moisture content. Material too dry for compaction shall have water added and mixed to obtain uniform moisture distribution. Material too wet for compaction shall be mixed and dried to obtain uniform moisture distribution. Backfill shall be placed in loose approximately horizontal layers not to exceed 6 inches, and compacted by mechanical means to ninety (95) percent of the Standard Proctor Test. Jetting will not be allowed. Backfill placed around pipes shall be placed in such a manner that the pipes will not be displaced or damaged. Backfill placed adjacent to pipes or appurtenances shall be compacted by hand operated power tampers. All backfill material shall be approved by the Engineer.

06200.8 SELECT BACKFILL

When the Engineer determines that material from the excavation is not suitable for backfill, select backfill shall be utilized and compensation will be negotiated under a change order.

06200.9 PAYMENT

With the exception of Select Backfill, the contract prices shall include full compensation for all costs incurred under this section.

SECTION 06900**WATER APPURTENANCE INSTALLATION, TESTING
AND DISINFECTION****06900.1 SCOPE**

This section covers the installation of all necessary fittings, valves and appurtenances for the water distribution system as shown on the plans and specified herein, testing and chlorination.

06900.2 HANDLING AND STORING MATERIALS

The Contractor shall use care unloading materials to avoid damage. Material shall not be rolled or dragged over gravel or rock during handling. The Contractor shall store the fittings, valves and appurtenances on sills above storm drainage level and deliver for installation after the trench is excavated. All valves shall be drained and so stored as to protect them from freezing. When any material is damaged during transporting, unloading, handling or storing, the undamaged portions may be used or, if damaged sufficiently, the Engineer will reject the material as being unfit for installation.

If any defective material is discovered after installation, it shall be removed and replaced with sound material or shall be repaired by the Contractor in an approved manner at his own expense.

06900.3 THRUST BLOCKS

All plugs, caps, tees, bends, and other fittings shall be provided with adequate thrust blocks. Thrust blocks shall be constructed to the minimum dimensions shown on the drawings or as directed. Thrust blocks shall be made of concrete having a compressive strength of twenty-eight (28) days of 3000 psi when tested in accordance with ASTM Specification C39 or C42 and shall bear directly against the undisturbed trench wall. Where possible, the backing shall be so placed that the fitting joints will be accessible for repair. All bolts and pipe joints shall be protected against contact with thrust block concrete by the installation of a polyethylene film placed between the fittings and the poured concrete. Where any section of a main is provided with concrete thrust blocks, the hydrostatic pressure test shall not be made until three (3) days after installation of the concrete thrust blocks unless otherwise approved by the Engineer. Where trench conditions are, in the opinion of the Engineer, unsuitable for thrust blocks, the Contractor shall provide steel tie rods and socket clamps to adequately anchor the piping. All tie rods and clamps shall be given a bituminous protective coating or shall be galvanized. Sakrete or any similar material will not be permitted under any circumstances.

06900.4 GATE VALVE INSTALLATION

Before setting each valve the Contractor shall make sure the interior is clean and test opening and closing. Valves shall be set with stems plumb, unless horizontal installation is called for on the plans, and at the exact locations shown. Trench backfill shall be tamped thoroughly for a distance of three (3) feet on each side of valve boxes.

06900.5 GATE VALVE BOX INSTALLATION

A valve box shall be installed over each underground valve. All boxes shall be set plumb with their top flush with finished grade.

06900.6 **FIRE HYDRANT INSTALLATION**

Fire hydrants shall be located as shown. Each hydrant shall be connected to the main with a six (6) inch branch line having at least as much cover as the distribution main. Hydrants shall be set plumb with the pumper nozzle facing the roadway and with the center of the lowest outlet not less than eighteen (18) inches above the finished grade. Hydrants shall be thoroughly blocked with concrete or shall be rodded to the six (6) inch branch tee. Unless otherwise specified, the backfill around hydrants shall be thoroughly compacted to the final grade immediately after installation in order to put the hydrant into service as soon as practicable. Not less than seven (7) cubic feet of clean crushed stone shall be placed around the base of the hydrant to insure drainage of the hydrant barrel. A cap block shall be set under the fire hydrant foot for a solid bottom.

06900.7 **AIR RELIEF VALVE INSTALLATION**

Each air relief valve shall be installed at the exact location shown per the detail. Meter boxes shall be set plumb and on a firm foundation. When meter boxes are precast concrete, each joint between sections and all wall openings shall be sealed inside and out with a 2:1 sand-cement mortar and made watertight. When so directed, the Contractor shall install a flat slab top, precast with a standard frame and cover. Flat slab tops shall be traffic bearing as appropriate.

06900.8 **BLOWOFF VALVES**

Blowoff valves shall be installed as shown on the contract drawings.

06900.9 **LINE FLUSHING**

Reference is made to AWWA C651. Prior to testing of any sections of water main, the Contractor, using an approved water source, shall completely flush out all lines at a minimum velocity of 2.5 feet per second to clean out any sediment or debris.

06900.10 **TESTING**

After the pipeline has been satisfactorily constructed complete with the required fire hydrants, services, and all other appurtenances, and the trench backfilled satisfactorily, and after line flushing and approval by the Engineer, the newly constructed pipeline and valved sections shall be subjected to a hydrostatic pressure leakage test. The Contractor shall notify the Engineer when the work is ready for testing with all testing done in the presence of the Engineer. All labor, equipment, water and materials, including meters and gauges shall be furnished by the Contractor at his own expense.

Ductile iron pipe will be tested in accordance with AWWA C600. PVC pipe will be tested in accordance with AWWA standard C-605 and Manual M-23.

Each completed section of the pipeline shall be plugged at both ends and slowly filled with water. As the main is being filled with water in preparation of the tests, all air shall be expelled from the pipe. The main shall be subjected to hydrostatic pressure of 200 pounds per square inch for a period of two (2) hours unless otherwise specified. Pressure shall be applied to the main by means of a hand pump for small lines or by use of a gasoline pump or fire engine for larger lines.

The rate of leakage shall be determined at fifteen (15) minute intervals by means of volumetric measurement of the water added during the test until the rate has stabilized at the constant value for three (3) consecutive fifteen (15) minute periods.

Leakage is defined as the quantity of water to be supplied into the newly laid pipe, or any valved section, necessary to maintain the specified leakage test pressure after the pipe has been filled with water and the air expelled. No piping installation will be accepted until the leakage is less than ten (10) gallons per inch of pipe diameter per mile of pipe per twenty-four (24) hours.

No leakage will be allowed under the above tests for piping in buildings and structures.

Cracked or defective pipe, joints, fittings, valves, or hydrants discovered in consequence of this test shall be removed and replaced with sound materials, and the test shall be repeated until the test results are satisfactory. Precautions shall be taken to remove or otherwise protect equipment in, or attached to, pipe to prevent damage or injury.

Tests of insulated and concealed piping shall be made before the piping is covered or concealed. No leakage will be allowed under the above tests for piping in buildings.

06900.11 DISINFECTION

After the pressure-leakage test is completed and prior to being put into service, new waterline shall be disinfected in strict accordance with AWWA Standard C651. The contractor shall submit a plan at least two weeks prior to the planned start of disinfection that describes in detail the following:

- Proposed form of chlorine to be used
- Proposed method of chlorination
- Final Flushing, including disposal of chlorinated water
- Bacteriological testing, including the name and address of the State approved lab to be used
- Redisinfection as necessary

Disinfection will not be permitted to begin until the plan is approved by the Engineer.

**North Carolina Department of Environment
And Natural Resources
Division of Environmental Health
Public Water Supply Section**

**Application for Approval
of Engineering Plans and Specifications
For Water Supply Systems**

Instructions & Checklist: To apply for approval for plans and specifications, submit the following materials & information:

Project Name: _____

(This is the name to appear on Public Water Supply records and tracking system)

Attached are three copies of each of the following items:

- ☐ This completed "Application for Approval...;"
- ☐ The plan drawings;
- ☐ The Engineering Report (ER) addressing each of the items listed in 15A NCAC 18C .0307(b), including the design basis of the project.[15A NCAC 18C .0307(b)(12)]

One of the following:

- ☐ The project will use the following system's previously approved standard specifications:

Name of System: _____

PWS Approval Number & Date: _____

OR

- ☒ Attached are three copies of the specifications.

One of the following:

- ☒ The applicant is the Public Water System;

OR

- ☐ Attached is a letter from the Owner of the Public Water System agreeing to serve the project and stating that the system has adequate supply.

Note the following:

- ☐ Beginning January 1, 2007, attached is a check for the proper plan review fee amount, in accordance with NCGS 130A-328. See note 4 on page 4.

Date _____
(for DENR use only)

Serial No. _____
(for DENR use only)

To: Division of Environmental Health,
Department of Environment and Natural Resources

The Utilities Director, Lee Smith
(name of board, or council, authorized official and title, or owner)

of City of Hendersonville
(name of city, town, corporation, sanitary district, water company or other)

in the County of Henderson, State of North Carolina authorized by law to act for the said

City of Hendersonville
(name of city, town, corporation, sanitary district, water company or other)

and to expend its funds for the water project described below, herewith submit for the counsel and advice of the Division of
Environmental Health plans and specifications prepared by _____
(engineer or firm)

(Phone Number of Engineer – optional for faster contact)

(Email Address of Engineer – optional for faster contact)

of _____ for the installation or construction of
(address of engineer)

(description of project)

(location of project)

in _____ County, and make application to the Division of Environmental Health for
the approval of said plans and specifications as related to public health and protection of public water supplies and public
water systems.

These plans have been approved and accepted by the applicant.

This application is made under and in full accord with the provision of NCGS 130A-317, and such other statutes as related to
public water systems. The applicant agrees that no change or deviation from the engineering plans and specifications
approved by the Division of Environmental Health will be made except as allowed by 15A NCAC 18C .0306 or with the
written consent and approval of the Division of Environmental Health or its authorized representative. The applicant agrees
that a professional engineer licensed to practice in the State of North Carolina shall submit a statement reflecting that
adequate observations during and upon completion of construction, by the engineer or by a representative of the engineer's
office who is under the engineer's supervision, indicates that construction was completed in accordance with approved plans
and specifications.

Remarks: _____

(Signature of Owner, Manager, Mayor or Chairman)

Lee Smith, Utilities Director
(Type Name Signed Above)

828-233-3211
(Phone Number – optional for faster contact)

305 Williams Street, Suite 119
(Street or Box Number)

Hendersonville, NC 28792
(City, State, Zip Code)

lsmith@cityofhendersonville.org
(Email Address – optional for faster contact)

Status of Water System Management Plan (WSMP)

Check one of the following, and if applicable, provide the required information:

- ☐ The WSMP for the project, as defined in the attached engineering plans and specifications, is submitted with this application.
- ☒ The WSMP that includes this project, as defined in the attached engineering plans and specifications, was previously submitted.

Provide the following:

Water System Name: City of Hendersonville

Owner Name: City of Hendersonville

PWS I.D. No.: 01-45-010

WSMP No.: 00-02080

WSMP Submittal Date: _____

County: Henderson

By my signature below, I certify that the previously submitted WSMP contains the information required by 15A NCAC 18C .0307(c) for the project defined in the attached engineering plans and specifications.

NAME: Lee Smith, Utilities Director
(Type or Print Name)

SIGNATURE: _____ DATE: _____
(Owner, Manager, Mayor or Chairman)

- ☐ The WSMP for the project, as defined in the attached engineering plans and specifications, has not been submitted.

Note: When the WSMP is submitted, the applicant must clearly identify the previously submitted project engineering plans and specifications for which the WSMP was prepared.

Status of Engineer's Report

Check one of the following, and if applicable, provide the required information.

- ☒ The Engineer's Report for the project, as defined in the attached engineering plans and specifications, is submitted with this application.
- ☐ The Engineer's Report that includes this project, as defined in the attached engineering plans and specifications, was previously submitted.

Provide the following:

Water System Name: _____

Owner Name: _____

PWS I.D. No.: _____

Engineer's Report No.: _____

Engineer's Report Title: _____

Engineer's Report Submittal Date: _____

County: _____

Note: If the previously submitted Engineer's Report covered multiple projects, then attach to this Application, a letter from the engineer stating that the previously submitted Engineer's Report contains the information required by 15A NCAC 18C .0307(b) for the project defined in the attached engineering plans and specifications.

In accordance with NCGS 130A-328, there will be a fee charged for plan review by the NC DENR Public Water Supply Section. **Any documents submitted for review on or after January 1, 2007 must be accompanied by a check payable to DENR-Public Water Supply Section before the review will begin.**

** There is a \$25 fee for returned checks **

The charges for review of plans are shown below. Check one of the following.

Distribution System fees

- | | | |
|--------------------------|-----------------------------------------------------------|--------------|
| <input type="checkbox"/> | Construction of water lines, less than 5000 linear feet | \$150 |
| <input type="checkbox"/> | Construction of water lines, 5000 linear feet or more | \$200 |
| <input type="checkbox"/> | Other construction or alteration to a distribution system | \$ 75 |

Ground Water System fees

- | | | |
|--------------------------|-------------------------------------------------------------------|--------------|
| <input type="checkbox"/> | Construction of a new ground water system or
adding a new well | \$200 |
| <input type="checkbox"/> | Alteration to an existing ground water system | \$100 |

Surface water system fees

- | | | |
|--------------------------|---------------------------------------------------------|--------------|
| <input type="checkbox"/> | Construction of a new surface water treatment facility | \$250 |
| <input type="checkbox"/> | Alteration to existing surface water treatment facility | \$150 |

Other fees

- | | | |
|--------------------------|--------------------------------------------------------|--------------|
| <input type="checkbox"/> | Water System Management Plan review | \$ 75 |
| <input type="checkbox"/> | Miscellaneous changes or maintenance not covered above | \$ 50 |

Notes:

1. The fee is not refundable if the plans are not approved
2. Revisions to plans to address PWS or other state agency's comments do not incur an additional fee.
3. If one set of plans has multiple related sheets, such as a new well with construction of water lines, only one fee must be submitted for highest price item (the amounts are not cumulative, except fees for Water System Management Plans).
4. Water System Management Plan review fees stand alone and must be included in addition to those for the review of the plans themselves.
5. **Ten days after the receipt of plans and specifications for approval, if the appropriate plan review fee is not received, then all plan documents will be recycled. A new set of documents must then be submitted with the appropriate fee for approval.**

These plans and specifications cited in the foregoing application, including any provisos in the approval letter, are approved insofar as the protection of public health is concerned as provided in the rules, standards and criteria adopted under the authority of NCGS 130A-315 and 130A-317. This approval does not address all applicable laws, rules, standards and criteria, and other approvals and licenses that may be required by the local, state or federal government.

This approval is given with the understanding that upon installation of such works, its operation shall be placed under the care of a competent person, and the operation shall be carried out according to best accepted practice and in accordance with the recommendations of the Division of Environmental Health.

The official copies of plans and specifications accompanying this application have been sealed and stamped with the serial number of this application _____. Any erasures, additions or alterations of the proposed improvements except those permitted in 15A NCAC 18C .0306 will make this approval null and void.

This approval does not constitute a warranty of the design, construction or future operation of the water system.

Signed: _____
Public Water Supply Section
Division of Environmental Health

**North Carolina Department of Environment
And Natural Resources
Division of Environmental Health
Public Water Supply Section**

**Application for Approval
of Engineering Plans and Specifications
For Water Supply Systems**

Instructions & Checklist: To apply for approval for plans and specifications, submit the following materials & information:

Project Name: _____

(This is the name to appear on Public Water Supply records and tracking system)

Attached are three copies of each of the following items:

- ☐ This completed "Application for Approval...;"
- ☐ The plan drawings;
- ☐ The Engineering Report (ER) addressing each of the items listed in 15A NCAC 18C .0307(b), including the design basis of the project.[15A NCAC 18C .0307(b)(12)]

One of the following:

- ☐ The project will use the following system's previously approved standard specifications:

Name of System: _____

PWS Approval Number & Date: _____

OR

- ☐ Attached are three copies of the specifications.

One of the following:

- ☐ The applicant is the Public Water System;

OR

- ☐ Attached is a letter from the Owner of the Public Water System agreeing to serve the project and stating that the system has adequate supply.

Note the following:

- ☐ Beginning January 1, 2007, attached is a check for the proper plan review fee amount, in accordance with NCGS 130A-328. See note 4 on page 4.

Date _____
(for DENR use only)

Serial No. _____
(for DENR use only)

To: Division of Environmental Health,
Department of Environment and Natural Resources

The _____
(name of board, or council, authorized official and title, or owner)

of _____
(name of city, town, corporation, sanitary district, water company or other)

in the County of _____, State of North Carolina authorized by law to act for the said

(name of city, town, corporation, sanitary district, water company or other)

and to expend its funds for the water project described below, herewith submit for the counsel and advice of the Division of
Environmental Health plans and specifications prepared by _____
(engineer or firm)

(Phone Number of Engineer – optional for faster contact)

(Email Address of Engineer – optional for faster contact)

of _____ for the installation or construction of
(address of engineer)

(description of project)

(location of project)

in _____ County, and make application to the Division of Environmental Health for
the approval of said plans and specifications as related to public health and protection of public water supplies and public
water systems.

These plans have been approved and accepted by the applicant.

This application is made under and in full accord with the provision of NCGS 130A-317, and such other statutes as related to
public water systems. The applicant agrees that no change or deviation from the engineering plans and specifications
approved by the Division of Environmental Health will be made except as allowed by 15A NCAC 18C .0306 or with the
written consent and approval of the Division of Environmental Health or its authorized representative. The applicant agrees
that a professional engineer licensed to practice in the State of North Carolina shall submit a statement reflecting that
adequate observations during and upon completion of construction, by the engineer or by a representative of the engineer's
office who is under the engineer's supervision, indicates that construction was completed in accordance with approved plans
and specifications.

Remarks: _____

(Signature of Owner, Manager, Mayor or Chairman)

(Street or Box Number)

(Type Name Signed Above)

(City, State, Zip Code)

(Phone Number – optional for faster contact)

(Email Address – optional for faster contact)

Status of Water System Management Plan (WSMP)

Check one of the following, and if applicable, provide the required information:

- ☐ The WSMP for the project, as defined in the attached engineering plans and specifications, is submitted with this application.
- ☐ The WSMP that includes this project, as defined in the attached engineering plans and specifications, was previously submitted.

Provide the following:

Water System Name: _____
Owner Name: _____
PWS I.D. No.: _____
WSMP No.: _____
WSMP Submittal Date: _____
County: _____

By my signature below, I certify that the previously submitted WSMP contains the information required by 15A NCAC 18C .0307(c) for the project defined in the attached engineering plans and specifications.

NAME: _____
(Type or Print Name)

SIGNATURE: _____ DATE: _____
(Owner, Manager, Mayor or Chairman)

- ☐ The WSMP for the project, as defined in the attached engineering plans and specifications, has not been submitted.

Note: When the WSMP is submitted, the applicant must clearly identify the previously submitted project engineering plans and specifications for which the WSMP was prepared.

Status of Engineer's Report

Check one of the following, and if applicable, provide the required information.

- ☐ The Engineer's Report for the project, as defined in the attached engineering plans and specifications, is submitted with this application.
- ☐ The Engineer's Report that includes this project, as defined in the attached engineering plans and specifications, was previously submitted.

Provide the following:

Water System Name: _____
Owner Name: _____
PWS I.D. No.: _____
Engineer's Report No.: _____
Engineer's Report Title: _____
Engineer's Report Submittal Date: _____
County: _____

Note: If the previously submitted Engineer's Report covered multiple projects, then attach to this Application, a letter from the engineer stating that the previously submitted Engineer's Report contains the information required by 15A NCAC 18C .0307(b) for the project defined in the attached engineering plans and specifications.

In accordance with NCGS 130A-328, there will be a fee charged for plan review by the NC DENR Public Water Supply Section. **Any documents submitted for review on or after January 1, 2007 must be accompanied by a check payable to DENR-Public Water Supply Section before the review will begin.**

** There is a \$25 fee for returned checks **

The charges for review of plans are shown below. Check one of the following.

Distribution System fees

- | | | |
|--------------------------|-----------------------------------------------------------|--------------|
| <input type="checkbox"/> | Construction of water lines, less than 5000 linear feet | \$150 |
| <input type="checkbox"/> | Construction of water lines, 5000 linear feet or more | \$200 |
| <input type="checkbox"/> | Other construction or alteration to a distribution system | \$ 75 |

Ground Water System fees

- | | | |
|--------------------------|-------------------------------------------------------------------|--------------|
| <input type="checkbox"/> | Construction of a new ground water system or
adding a new well | \$200 |
| <input type="checkbox"/> | Alteration to an existing ground water system | \$100 |

Surface water system fees

- | | | |
|--------------------------|---------------------------------------------------------|--------------|
| <input type="checkbox"/> | Construction of a new surface water treatment facility | \$250 |
| <input type="checkbox"/> | Alteration to existing surface water treatment facility | \$150 |

Other fees

- | | | |
|--------------------------|--------------------------------------------------------|--------------|
| <input type="checkbox"/> | Water System Management Plan review | \$ 75 |
| <input type="checkbox"/> | Miscellaneous changes or maintenance not covered above | \$ 50 |

Notes:

1. The fee is not refundable if the plans are not approved
2. Revisions to plans to address PWS or other state agency's comments do not incur an additional fee.
3. If one set of plans has multiple related sheets, such as a new well with construction of water lines, only one fee must be submitted for highest price item (the amounts are not cumulative, except fees for Water System Management Plans).
4. Water System Management Plan review fees stand alone and must be included in addition to those for the review of the plans themselves.
5. **Ten days after the receipt of plans and specifications for approval, if the appropriate plan review fee is not received, then all plan documents will be recycled. A new set of documents must then be submitted with the appropriate fee for approval.**

These plans and specifications cited in the foregoing application, including any provisos in the approval letter, are approved insofar as the protection of public health is concerned as provided in the rules, standards and criteria adopted under the authority of NCGS 130A-315 and 130A-317. This approval does not address all applicable laws, rules, standards and criteria, and other approvals and licenses that may be required by the local, state or federal government.

This approval is given with the understanding that upon installation of such works, its operation shall be placed under the care of a competent person, and the operation shall be carried out according to best accepted practice and in accordance with the recommendations of the Division of Environmental Health.

The official copies of plans and specifications accompanying this application have been sealed and stamped with the serial number of this application _____. Any erasures, additions or alterations of the proposed improvements except those permitted in 15A NCAC 18C .0306 will make this approval null and void.

This approval does not constitute a warranty of the design, construction or future operation of the water system.

Signed: _____
Public Water Supply Section
Division of Environmental Health

**PROJECT SUMMARY
WATER UTILITY EXTENSION
Sanctuary at Mills River**

February 22, 2008

To: Honorable Mayor and Members of City of Council

From: Water & Sewer Department Staff

RE: STAFF RECOMMENDATION FOR ACCEPTANCE OF
WATER UTILITY EXTENSION AGREEMENT (WUEA)

This is a project to extend lines to provide water service to a **proposed single-family residential development consisting of 10 units on 11 acres**. This project is located on **North Rugby Road**. This project is under the reviewing jurisdiction of **Henderson County** and is located within the **USA – Urban Services Area**. This project **will not** involve an IBT (Interbasin Transfer) from the French Broad River Basin. The entire cost of the proposed water line extension is to be paid for by **M & M Land Developer's of WNC, LLC., of Hendersonville, NC**.

This project requires approximately **1,700** linear feet of water line sized as following:

Approximate Length:	Description:
180 lf	8" DIP CL 350
1,000 lf	6" DIP CL 350
500 lf	2" SDR 13.5 PVC

Fire Protection will be provided by the installation of **2-fire hydrant(s)**.

The Reviewing Jurisdiction, listed below, has completed their review of this utility extension request in regard to their adopted land use plan or in terms of its future impact on existing land uses for that local government.

Reviewing Jurisdiction: **Henderson County**

☐ Approved ☐ Disapproved (See attached letter provided to the City by the Reviewing Jurisdiction)

Narrative Comments Provided: ☐ Yes ☐ No

Signing of Official: _____
Printed Name: _____



Date: _____

Based on the above information, the Water & Sewer Department has the capacity to support this additional infrastructure and associated connections and hereby recommends approval of said project contingent upon final approval of construction plans and specifications by the Water & Sewer Department.

A motion is needed to approve and accept this project. Suggested wording for motion is as follows:

"I move to accept this Water Utility Extension Project and to authorize the City Manager to execute the associated Water Utility Extension Agreement on behalf of the City."

Water and Sewer Department:	<input checked="" type="checkbox"/> Approved	<input type="checkbox"/> Disapproved	Date: 2-28-08
Henderson Co. Commissioners:	<input type="checkbox"/> Approved	<input type="checkbox"/> Disapproved	Date: _____
Hendersonville City Council:	<input type="checkbox"/> Approved	<input type="checkbox"/> Disapproved	Date: _____



WILLIAM G. LAPSLEY & A ASSOCIATES P.A.
Consulting Engineers & Land Planners
Two Town Square Blvd. Suite 200
Asheville, North Carolina 28803
(800) 687-7777 (919) 687-7778
www.wgl.com

Revisions	

date:1/08

job: 08104

drawn: KHC










PROPOSED
PROMISED RIDGE
ROAD PROFILE

THE SANCTUARY AT MILLS RIVER
HENDERSON COUNTY,
NORTH CAROLINA

WILLIAM G. LAPSLEY & A ASSOCIATES P.A.
CONSULTING ENGINEERS & LAND PLANNERS
ASHEVILLE, NORTH CAROLINA





NOTES:
1. WATER LINE TO BE 3 FEET FROM EDGE OF PAVEMENT.

DEVELOPMENT DATA
ZONING - R-2
HENDERSON COUNTY
SETBACKS-
FRONT- 15 FT
SIDE- 10 FT
REAR- 10 FT
WATER- SUPPLY WATERSHED WS IV

SURVEYOR:
STACY K. RHODES, PLS
WAGGONER & RHODES
LAND SURVEYORS, INC.
346 OLD SPARTANBURG RD
HENDERSON, NC 28792
828-833-1022

OWNER/DEVELOPER
M&M LAND DEVELOPERS OF WNC, LLC
3702 SPARTANBURG HWY
FLAT ROCK, NC 28731
PIN: 9650-19-5722
PIN: 9650-19-0825
DB: 1341, PG 396

Revisions









date:1/30
job: 08104
drawn: KHC



THE SANCTUARY AT MILLS RIVER
HENDERSON COUNTY,
NORTH CAROLINA

WILLIAM G. LAPSLEY & A ASSOCIATES P.A.
CONSULTING ENGINEERS & LAND PLANNERS
ASHEVILLE, NORTH CAROLINA



[illegible][illegible][illegible]

NC ONE CALL CENTER
CALL BEFORE YOU DIG
1-800-652-4949

**SANCTUARY AT MILLS
HENDERSON COUNTY,
NORTH CAROLINA**

Size	Q_{CS}	Q_{new}
DPE	96.42 cfs	111.26 cfs
DPE	18'0"	22.75 cfs
DPE	18'0"	0.95 cfs
DPE	14'0"	1.03 cfs
DPE		22.75 cfs

Classification	Listing
20 lbs.	Grass
20 lbs.	Sun. Grass
20 lbs.	Grass
10 lbs.	Sun. Grass
10 lbs.	Grass
50 lbs.	Grass
50 lbs.	Sun. Grass
50 lbs.	Sun. Grass

11/1/00

sheet
3 of 3

HENDERSON COUNTY REVIEW OF CITY WATER LINE EXTENSIONS

Project Name: Sanctuary at Mills River
Size of Water Line (Main & Distribution Pipe Size): 1,700 lf (180 lf 8" DIP CL 350; 1,000 lf 6" DIP CL 350; 500 lf 2" SDR 13.5 PVC)
County Staff Reviewing Extension: Rocky Hyder, Fire Marshal; Alexis Baker, Planner; Autumn Radcliff, Senior Planner

Has the project been reviewed under the **County Subdivision Regulations of the Land Development Code?** ☒ Yes ☐ No ☐ N/A
Date reviewed: 2/26/2008
Action: Conditional Letter of Approval for Minor Subdivision Development Plan
Conditions: Shoulder stabilization, road name approval, and additional final plat requirements
Comments:

Has the project been reviewed under the **County Manufactured Park Regulations of the Land Development Code?** ☐ Yes ☒ No ☐ N/A
Date reviewed: _____
Action: _____
Conditions: _____
Comments:

Has the project been reviewed under the **County Zoning Regulations (i.e. Special-Use or Conditional-Use Permit) of the Land Development Code?** ☐ Yes ☒ No ☐ N/A
Date reviewed: _____
Action: _____
Conditions: _____
Comments:

Is the project subject to **any other County Land Use Regulations?** ☐ Yes ☒ No ☐ N/A
If yes, explain:

Does the project conform with the **2020 Henderson County Comprehensive Plan (CCP)?** ☒ Yes ☐ No ☐ N/A

The project lies in the Urban Services Area.

Does the project have **adequate hydrant location and spacing?** ☒ Yes ☐ No ☐ N/A

Description of **hydrant type and thread:** Mueller Centurion – National Standard Thread

Does the estimated flow rate (gpm) meet **fire protection standards?** The estimated flow rate of 500 gpm requires structure spacing of more than 100 feet. ☐ Yes ☒ No ☐ N/A

BOARD OF COMMISSIONERS APPROVAL

- ☐ Approved
☐ Not Approved
☐ Conditional Approval (See Comments)

Date of Board Review: _____
Comments: