WGLA Engineering, PLLC 724 5th Avenue West Hendersonville, NC 28739 (828) 687-7177 wgla.com

Addendum #1

2020 Paving Improvements for Henderson County Public Schools February 27, 2020

This Addendum shall be attached to and made a part of the above named Contract Documents.

The following items are issued to, modify, and clarify the Contract Documents. These items shall have full force and effect as the Contract Documents, and cost involved shall be included in the Bid prices. Bids, to be submitted on the specified date, shall conform to the additions and revisions listed herein. Acknowledge receipt of the Addendum on the Bid. Failure to do so may subject the bidder to disqualification.

ADDENDUM ITEMS

- The paving layout and quantities for East Henderson High School Area "D" as seen on Sheet C-200 has changed. Revision bubbles have been applied to areas/quantities that changed on Sheet C-200. Please see the revised drawings located on Dropbox at: https://www.dropbox.com/sh/c55skpmk2mr4a6g/AAD23X3loysI3CRdYvslL9IAa?dl=0
- 2. The bid form has been updated to 2-27-2020 to reflect Addendum #1. Please use the revised bid form as items #13-#18 for East Henderson High School Area "D" have changed.
- 3. As a clarification to note #2 of Sheet C-400, "Pavement striping & numbering to be performed by contractor and is to match existing. Striping should consist of two (2) coats of asphalt pavement paint." Not all drawing sheets show the proposed pavement striping. One example is Sheet C-302, this area will get repaired and overlaid but will need to be restriped to match existing striping configurations. Contractor is responsible for layout and paint striping to match existing. The bid form has line items for striping for each of the project areas.

END OF ADDENDUM #1