


Addendum #2		
CLARK NEXSEN		
301 College Street, Suite 300		
Asheville, NC 28801		
Date:	12/9/2020	
Project #	5199-L	
Project	BRCC - Public Safety Training Facility	
<p>Where any article, division or subparagraph of the original contract documents or other addenda is supplemented herein, the provisions of the original documents shall remain in effect. All the supplemental provisions shall be considered as added thereto. Where any such article, division or subparagraphs are amended, voided or superseded thereby, the provisions of such article, division or subparagraph not so specifically amended, voided or superseded shall remain in effect.</p>		
<p>The attention of each Contractor is called to the following clarifications; additions to and changes in the plans and specifications dated NOVEMBER 17, 2020 on the above job. It will be the responsibility of each Contractor to call such clarifications, additions and changes in plans and specifications to the attention of subcontractors concerned. The Architect in no way assumes any responsibility for notifying any subcontractor, material dealers or others not having received the original contract documents.</p>		
Item#	Question / Answer	
1	Question:	Spec section 12300, Alternate E-1, Description appears to reference notes not contained on the drawings.
	Answer:	Remove Alternate E-1 (in building emergency communications system) from the project. Remove specification section 275319 from the project. So that we don't have to reissue the form of proposal, simply write in a cost of zero dollars for Alternate E-1 on the form. Include in the base bid (2) 2" conduits with pull string from electrical room to underside of roof decking.
Attachments and all items below shall be included in the contract		
The following drawings(s) have been modified or added as part of Addendum#2		
None		
The following specification sections have been modified or added as part of Addendum#2		
None		