

Henderson County Capital Projects

100 North King Street, Suite 206 Hendersonville, North Carolina 28792

Memorandum To:	Pre-Bid Meeting Attendees
From:	Thad Ninnemann Capital Projects Project Manager
Subject:	Addendum #1 BRCC Sink Building Boiler Repairs

Addendum #1 BRCC Sink Building Boiler Repairs

Questions and Clarifications

Question: Alternate #4- Does BRCC want the existing piping labels to be replaced or just new ones added every ten feet?

Answer: Leave the existing piping labels and add new labels every 10'

Question: Please explain further how the project will be awarded with the alternates selected/chosen and the base bid.

Answer: We could choose up to 4 alternates depending on the Base Bid.