


### SECOND FLOOR PLAN — POWER & RECEPTACLE

SCALE: 1/8" = 1'-0"



### SOUND SYSTEM RISER DIAGRAM

NOTE TO SCALE

PANEL " B " SCHEDULE		Description/Remarks: SQUARE FEET: 42,411.200/ROVOLT 3/4 AWG, 225 AMP MAIN LIFT ONLY, 2/11, FLUSH FITZ *STUBS 4-1/2" TO ABOVE CLG. FOR FUTURE USE AREA SERVED SQUARE FEET: DEMAND FACTOR: 1/4; COMPUTED LOAD KW									
Connected load: 79 Kw.											
Wire: 4#1/0											
Conduit: 2\"/>											
DESCRIPTION	Cond.	Wire	Load	Breaker	CIRCUIT NUMBER	Breaker	Load	Wire	Cond.	DESCRIPTION	
FLOOR LTR. MTR. RM. 209	1/2"	925	1P.20	1	A	2	1P.20	1000	3#12	REC. MTR. RM. 209	
FLOOR LTR. MTR. RM. 209	1/2"	925	1P.20	3	B	4	1P.20	900	3#12	REC. MTR. RM. 209	
FLOOR LTR. MTR. RM. 209	1/2"	925	1P.20	5	C	6	1P.20	700	2#12 1/2"	P.A. SYSTEM MTR. RM. 209	
TRACK LTR. MTR. RM. 209	1/2"	450	1P.20	7	A	8	1P.20	1000	3#12	REC. MTR. RM. CHNL. 209	
TRACK LTR. MTR. RM. 209	1/2"	312	1P.20	9	B	10	1P.20	1000	1/2"	REC. MTR. RM. CHNL. 209	
WALL MTR. RM. 209	1/2"	2812	1P.20	11	C	12	1P.20	1000	2#12 1/2"	REC. CORRS. LOBBY, VP	
LTR. CHAIRMAN 207	1/2"	925	1P.20	13	A	14	1P.20	900	3#12	REC. CORRS. LOBBY, VP	
LTR. CHAIRMAN 207	1/2"	4812	1P.20	15	B	16	1P.20	900	3#12	REC. OFF. 216, 217	
LTR. ENTRY RM. 202	1/2"	2812	1P.20	17	A	18	1P.20	900	3#12	REC. OFF. 216, 217	
LTR. OFFICE 217	1/2"	1110	1P.20	19	B	20	1P.20	900	3#12	REC. OFF. 215, 219	
LTR. OFFICE 216	1/2"	1110	1P.20	21	C	22	1P.20	900	3#12	REC. OFF. 215, 219	
LTR. CORR. 205, 204	1/2"	2812	1P.20	23	A	24	1P.20	900	1/2"	REC. OFF. 215, 219	
LTR. OFFICE 215	1/2"	725	1P.20	25	B	26	1P.20	500	2#12 1/2"	FIRE ALARM PANEL	
LTR. OFFICE 215	1/2"	925	1P.20	27	C	28	2P	2KV	2#12	ELECT. WATER HEATER	
LTR. TR. JAN.	1/2"	2812	1P.20	29	A	30	2P	5.0	1/2"	SPACE ONLY	
2P. FL. W/OUT. ENDS	1/2"	2812	1P.20	31	B	32	2P	5.0	1/2"	SPACE ONLY	
SPARE				33	C	34					
				35	C	36					
				37	B	38					
				39	B	40					
				41	C	42					