



## Henderson County Capital Projects

100 North King Street, Suite 206  
Hendersonville, North Carolina 28792

---

*Memorandum To:* Pre-Bid Meeting Attendees

*From:* Bryan Rhodes  
Capital Projects Project Manager

*Subject:* Addendum #2

*Date:* November 14, 2022

---

TEDC Replace Chiller #2

Addendum #2 Question and Clarification

Question: Regarding the refrigerant in the existing Chiller: Do you wish to keep the refrigerant? If so, who will be providing the Refrigerant containers?

Answer: BRCC does not want the refrigerant. The evacuated refrigerant will belong to the Contractor and will be the Contractor's responsibility to take the refrigerant with him and dispose of off-site. It will be the responsibility of the Contractor to provide all equipment, materials, and tanks to perform the proper decommission/refrigerant evacuation per OSHA Standards as part of the project.