

### **Addendum #1 Spearman Small Storage Building for Auto**

Question: As we observed the existing bollards are flange mounted in the surface of parking at grade. I would like to ask if we may simply set/plant the bollards for the new structure in the subgrade? Naturally, we would set each to a minimal subgrade depth of 30" and then compact and pour along with other concrete to meet the existing surface at grade.

Answer: Yes, if the bollards are the same diameter and height as the bollards on the existing storage building. Please remember that the bollards are Alternate #1 and are not part of the Base bid.